


REPORT

TRUESDAIL LABORATORIES, INC.

CHEMISTS - MICROBIOLOGISTS - ENGINEERS
RESEARCH - DEVELOPMENT - TESTING



14201 FRANKLIN AVENUE
TUSTIN, CALIFORNIA 92680
AREA CODE 714 • 730-6239
AREA CODE 213 • 225-1564
CABLE: TRUE LABS

CLIENT **Douglas Aircraft Company**
Internal Mail Code 211-46
3855 Lakewood Boulevard
Long Beach, California 90846
SAMPLE Attention: Kathleen Faretta
Monthly Storm Drain Inspection - March, 1990
P.O. No.: T & M 23465C

DATE March 28, 1990
RECEIVED March 28, 1990
LABORATORY NO. 36429

INVESTIGATION

As requested by the CRWQCB for NPDES
permit numbers CA0001406 and CA0001414

RESULTS

A representative of Truesdail Laboratories, Inc., tested the storm drain discharge on March 28, 1990, at the Douglas Long Beach facility (003) and Torrance facilities. The discharge was tested for flow rate, pH, and temperature. The results are as follows:

<u>Sample I.D.</u>	<u>Date</u>	<u>Time</u>	<u>Flow-gpd</u>	<u>Temp, °F</u>	<u>pH, units</u>
Long Beach (003)	3/28/90	2:00	72,633	47	7.5
Torrance	3/28/90	11:35	357	50	6.5

Respectfully submitted,
TRUESDAIL LABORATORIES, INC.

Luis Perez, Supervisor
Industrial Waste